

Volatile Organics-Sample Date: 12/4/00; Sampled by: C Truitt; Sample ID: OL001084; Lab: WSLH

| Storet Code | Description | Result | Units | Qualifier | MCL | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|--------------------------------|--------|-------|------------|------|-----------|-----------------------|--------------------|---------------|
| 2990 | BENZENE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 1 |
| 2993 | BROMOBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 2 |
| 2430 | BROMOCHLOROMETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 3 |
| 2943 | BROMODICHLOROMETHANE | 0 | UG/L | Non-detect | 80 | UG/L | 0.5 | 0.15 | 4 |
| 2942 | BROMOFORM | 0 | UG/L | Non-detect | 80 | UG/L | 0.5 | 0.15 | 5 |
| 2214 | BROMOMETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 6 |
| 2422 | N-BUTYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 7 |
| 2428 | SEC-BUTYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 8 |
| 2426 | TERT-BUTYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 9 |
| 2982 | CARBON TETRACHLORIDE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 10 |
| 2216 | CHLOROETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 11 |
| 2941 | CHLOROFORM | 0 | UG/L | Non-detect | 80 | UG/L | 0.5 | 0.15 | 12 |
| 2210 | CHLOROMETHANE (METHYLCHLORIDE) | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 13 |
| 2965 | O-CHLOROTOLUENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 14 |
| 2966 | P-CHLOROTOLUENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 15 |
| 2944 | DIBROMOCHLOROMETHANE | 0 | UG/L | Non-detect | 80 | UG/L | 0.5 | 0.15 | 16 |
| 2931 | 1,2-DIBROMO-3-CHLOROPRO.(DBCP) | 0 | UG/L | Non-detect | 0.2 | UG/L | 0.66 | 0.2 | 17 |
| 2408 | DIBROMOMETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 18 |
| 2967 | M-DICHLOROBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 19 |
| 2968 | O-DICHLOROBENZENE | 0 | UG/L | Non-detect | 600 | UG/L | 0.5 | 0.15 | 20 |
| 2969 | P-DICHLOROBENZENE | 0 | UG/L | Non-detect | 75 | UG/L | 0.5 | 0.15 | 21 |
| 2212 | DICHLORODIFLUOROMETHANE | 0 | UG/L | Non-detect | | UG/L | 0.66 | 0.2 | 22 |
| 2978 | 1,1-DICHLOROETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 23 |
| 2980 | 1,2-DICHLOROETHANE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 24 |
| 2977 | 1,1-DICHLOROETHYLENE | 0 | UG/L | Non-detect | 7 | UG/L | 0.5 | 0.15 | 25 |
| 2380 | CIS-1,2-DICHLOROETHYLENE | 0 | UG/L | Non-detect | 70 | UG/L | 0.5 | 0.15 | 26 |
| 2979 | TRANS-1,2-DICHLOROETHYLENE | 0 | UG/L | Non-detect | 100 | UG/L | 0.5 | 0.15 | 27 |
| 2964 | DICHLOROMETHANE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 28 |
| 2983 | 1,2-DICHLOROPROPANE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 29 |
| 2412 | 1,3-DICHLOROPROPANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 30 |
| 2416 | 2,2-DICHLOROPROPANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 31 |
| 2410 | 1,1-DICHLOROPROPENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 32 |
| 2413 | 1,3-DICHLOROPROPENE | 0 | UG/L | Non-detect | | UG/L | | | 33 |
| 2228 | CIS-1,3-DICHLOROPROPENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 34 |
| 2224 | TRANS-1,3-DICHLOROPROPENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 35 |
| 2992 | ETHYLBENZENE | 0 | UG/L | Non-detect | 700 | UG/L | 0.5 | 0.15 | 36 |
| 2946 | ETHYLENE DIBROMIDE (EDB) | 0 | UG/L | Non-detect | 0.05 | UG/L | 0.5 | 0.15 | 37 |
| 2246 | HEXACHLOROBUTADIENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 38 |
| 2994 | ISOPROPYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 39 |
| 2030 | P-ISOPROPYLTOLUENE (P-CYMENE) | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 40 |
| 2251 | METHYL-TERT-BUTYL-ETHER | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 41 |

| | | | | | | | | | |
|------|--------------------------------|---|------|------------|-------|------|------|------|----|
| 2989 | MONOCHLOROBENZENE (CHLOROBE..) | 0 | UG/L | Non-detect | 100 | UG/L | 0.5 | 0.15 | 42 |
| 2248 | NAPHTHALENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 43 |
| 2998 | N-PROPYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 44 |
| 2996 | STYRENE | 0 | UG/L | Non-detect | 100 | UG/L | 0.5 | 0.15 | 45 |
| 2986 | 1,1,1,2-TETRACHLOROETHANE | 0 | UG/L | Non-detect | | UG/L | 0.66 | 0.2 | 46 |
| 2988 | 1,1,2,2-TETRACHLOROETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 47 |
| 2987 | TETRACHLOROETHYLENE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 48 |
| 2991 | TOLUENE | 0 | UG/L | Non-detect | 1000 | UG/L | 0.5 | 0.15 | 49 |
| 2420 | 1,2,3-TRICHLOROBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 50 |
| 2378 | 1,2,4-TRICHLOROBENZENE | 0 | UG/L | Non-detect | 70 | UG/L | 0.5 | 0.15 | 51 |
| 2981 | 1,1,1-TRICHLOROETHANE | 0 | UG/L | Non-detect | 200 | UG/L | 0.5 | 0.15 | 52 |
| 2985 | 1,1,2-TRICHLOROETHANE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 53 |
| 2984 | TRICHLOROETHYLENE | 0 | UG/L | Non-detect | 5 | UG/L | 0.5 | 0.15 | 54 |
| 2218 | TRICHLOROFLUOROMETHANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 55 |
| 2414 | 1,2,3-TRICHLOROPROPANE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 56 |
| 2418 | 1,2,4-TRIMETHYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 57 |
| 2424 | 1,3,5-TRIMETHYLBENZENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 58 |
| 2950 | TTHM | 0 | UG/L | Non-detect | 80 | UG/L | | | 59 |
| 2976 | VINYL CHLORIDE | 0 | UG/L | Non-detect | 0.2 | UG/L | 0.66 | 0.2 | 60 |
| 2997 | O-XYLENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 61 |
| 2962 | P-XYLENE | 0 | UG/L | Non-detect | | UG/L | 0.5 | 0.15 | 62 |
| 2955 | XYLENES, TOTAL | 0 | UG/L | Non-detect | 10000 | UG/L | | | 63 |