

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

H. Laessig, Ph.D., Director

D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

MALISCH, RICHARD  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 09/23/04  
Sample location: 5606 RIVER ROAD, WAUNAKEE  
KINDERGARTEN FOUNTAIN

Collector: R MALISCH

Date Received: 09/23/04  
Lab slip Number: IP009047

Date Completed: 09/30/04  
Date Released: 10/04/04

-----  
Test Results

Lead, SDWA*	<1	UG/L
Copper, SDWA*	131.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

H. Laessig, Ph.D., Director

D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

MALISCH, RICHARD  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 09/23/04  
Sample location: 5606 RIVER ROAD, WAUNAKEE  
PRE-K HALL FOUNTAIN

Collector: R MALISCH

Date Received: 09/23/04  
Lab slip Number: IP009046

Date Completed: 09/30/04  
Date Released: 10/04/04

-----  
Test Results

Lead, SDWA*	2.0	UG/L
Copper, SDWA*	192.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene

University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

H. Laessig, Ph.D., Director

D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

MALISCH, RICHARD  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 09/23/04  
Sample location: 5606 RIVER ROAD, WAUNAKEE  
PE FOUNTAIN

Collector: R MALISCH

Date Received: 09/23/04  
Lab slip Number: IP009045

Date Completed: 09/30/04  
Date Released: 10/04/04

-----  
Test Results

Lead, SDWA*	3.8	UG/L
Copper, SDWA*	261.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

H. Laessig, Ph.D., Director

D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

MALISCH, RICHARD  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 09/23/04  
Sample location: 5606 RIVER ROAD, WAUNAKEE  
MUSIC FOUNTAIN

Collector: R MALISCH

Date Received: 09/23/04  
Lab slip Number: IP009044

Date Completed: 09/30/04  
Date Released: 10/04/04

-----  
Test Results

Lead, SDWA*	3.0	UG/L
Copper, SDWA*	202.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

H. Laessig, Ph.D., Director

D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

MALISCH, RICHARD  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 09/23/04  
Sample location: 5606 RIVER ROAD, WAUNAKEE  
FACULTY SINK

Collector: R MALISCH

Date Received: 09/23/04  
Lab slip Number: IP009043

Date Completed: 09/30/04  
Date Released: 10/04/04

-----  
Test Results

Lead, SDWA*	<1	UG/L
Copper, SDWA*	58.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.