

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

Charles D. Brokopp, Dr.P.H., Director      D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section      (608) 224-6277      DNR LAB ID 113133790

CAVITT, TOM  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 08/17/07      Collector: T CAVITT  
Sample location: MADISON COUNTRY DAY SCHOOL, WAUNAKEE  
STAFF LOUNGE SINK

Comment: TIER EXCEPTIONAL

Date Received: 08/17/07      Date Completed: 09/10/07  
Lab slip Number: IS004637      Date Released: 09/11/07

-----  
Test Results

Lead, SDWA*	3.1	UG/L
Copper, SDWA*	27.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

Charles D. Brokopp, Dr.P.H., Director      D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section

(608) 224-6277

DNR LAB ID 113133790

CAVITT, TOM  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 08/17/07

Collector: T CAVITT

Sample location: MADISON COUNTRY DAY SCHOOL, WAUNAKEE  
LIBRARY (ROOM 202) SINK DRINKING FOUNTAIN

Comment: TIER EXCEPTIONAL

Date Received: 08/17/07

Date Completed: 09/10/07

Lab slip Number: IS004641

Date Released: 09/11/07

-----  
Test Results

Lead, SDWA*	2.1	UG/L
Copper, SDWA*	79.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

Charles D. Brokopp, Dr.P.H., Director      D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section      (608) 224-6277      DNR LAB ID 113133790

CAVITT, TOM  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 08/17/07      Collector: T CAVITT  
Sample location: MADISON COUNTRY DAY SCHOOL, WAUNAKEE  
ROOM 102 SINK DRINKING FOUNTAIN

Comment: TIER EXCEPTIONAL

Date Received: 08/17/07      Date Completed: 09/10/07  
Lab slip Number: IS004640      Date Released: 09/11/07

-----  
Test Results

Lead, SDWA*	3.0	UG/L
Copper, SDWA*	294.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

State Laboratory of Hygiene  
University of Wisconsin

2601 Agriculture Drive, PO Box 7996, Madison, WI 53707-7996

Charles D. Brokopp, Dr.P.H., Director      D.F. Kurtycz, M.D., Medical Director

-----  
Environmental Science Section      (608) 224-6277      DNR LAB ID 113133790

CAVITT, TOM  
5606 RIVER RD  
WAUNAKEE

WI 53597

Facility ID#: 113055800  
Billing #: 7005

Collection date: 08/17/07      Collector: T CAVITT  
Sample location: MADISON COUNTRY DAY SCHOOL, WAUNAKEE  
ROOM 112 SINK DRINKING FOUNTAIN

Comment: TIER EXCEPTIONAL

Date Received: 08/17/07      Date Completed: 09/10/07  
Lab slip Number: IS004639      Date Released: 09/11/07

-----  
Test Results

Lead, SDWA*	<1	UG/L
Copper, SDWA*	48.	UG/L

\* Safe Drinking Water Act

Note: the "<" symbol (if it is used here) stands for "less than" the limit of detection, which for these tests is 1 ug/L for lead and 5 ug/L (0.005 mg/L) for copper.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>.

