

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-01
Sample Site: Main Office Fountain

Date Collected: September 10, 2008

Date Received: September 11, 2008

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B-19th	4.00	17.0	18-Sep-08	79.8	ug/L	1300	
Lead, Total	SM 3113 B-19th	0.22	0.83	18-Sep-08	<0.22	ug/L	15	

Submitted by:

Davy Laboratories

A handwritten signature in black ink, appearing to read "Paul A. Harris", written over a horizontal line.

Paul A. Harris, Laboratory Director

The laboratory analyses reported above were determined in accordance with methods from approved authoritative sources. Approved authoritative sources are defined and listed within the respective state certification codes. The results are representative of the samples only; conditions can be expected to vary at different times and under different sampling conditions. This report may not be reproduced, except in full, without the written approval of the laboratory. WI Certification Nos. 632021390 and 105000216, MN Certification No. 055-999-151, IA Certification No. 304

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-02
Sample Site: Pre K Fountain

Date Collected: September 10, 2008

Date Received: September 11, 2008

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B-19th	4.00	17.0	18-Sep-08	198	ug/L	1300	
Lead, Total	SM 3113 B-19th	0.22	0.83	18-Sep-08	2.83	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-03
Sample Site: Pod Fountain

Date Collected: September 10, 2008

Date Received: September 11, 2008


Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
-----------	--------	-----	--------	----------	--------	-------	-----	-----------

SDWA Inorganic Analysis

Copper, Total	SM 3111 B-19th	4.00	17.0	18-Sep-08	344	ug/L	1300	
Lead, Total	SM 3113 B-19th	0.22	0.83	18-Sep-08	2.07	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-04
Sample Site: Music Fountain

Date Collected: September 10, 2008

Date Received: September 11, 2008

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B-19th	4.00	17.0	18-Sep-08	138	ug/L	1300	
Lead, Total	SM 3113 B-19th	0.22	0.83	18-Sep-08	8.18	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-05
Sample Site: Kindergarten Fountain

Date Collected: September 10, 2008

Date Received: September 11, 2008

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B-19th	4.00	17.0	18-Sep-08	185	ug/L	1300	
Lead, Total	SM 3113 B-19th	0.22	0.83	18-Sep-08	3.74	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: September 23, 2008
Client No: 10305

Sample No: 8090451-06
Sample Site: Pump Room

Date Collected: September 10, 2008

Date Received: September 11, 2008

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Nitrate as N	EPA 300.0	0.200	0.600	12-Sep-08	5.99	mg/L	10	