

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: December 16, 2010
Client No: 10305


Sample No: 0120289-04
Sample Site: Maint Office Fountain

Date Collected: December 07, 2010 Date Received: December 08, 2010

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B 19th Edition	5.00	17.0	15-Dec-10	170	ug/L	1300	
Lead, Total	SM 3113 B 19th Edition	0.15	0.57	15-Dec-10	<0.15	ug/L	15	

Submitted by:

Davy Laboratories


Paul A. Harris, Laboratory Director

The laboratory analyses reported above were determined in accordance with methods from approved authoritative sources. Approved authoritative sources are defined and listed within the respective state certification codes. The results are representative of the samples only; conditions can be expected to vary at different times and under different sampling conditions. This report may not be reproduced, except in full, without the written approval of the laboratory. WI Certification Nos. 632021390 and 105000216, MN Certification No. 055-999-151, IA Certification No. 304

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: December 16, 2010
Client No: 10305

Sample No: 0120289-02
Sample Site: Pre K Fountain

Date Collected: December 07, 2010

Date Received: December 08, 2010

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B 19th Edition	5.00	17.0	15-Dec-10	334	ug/L	1300	
Lead, Total	SM 3113 B 19th Edition	0.15	0.57	15-Dec-10	3.85	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: December 16, 2010
Client No: 10305

Sample No: 0120289-03
Sample Site: Pod Fountain

Date Collected: December 07, 2010

Date Received: December 08, 2010

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B 19th Edition	5.00	17.0	15-Dec-10	430	ug/L	1300	
Lead, Total	SM 3113 B 19th Edition	0.15	0.57	15-Dec-10	3.32	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: December 16, 2010
Client No: 10305

Sample No: 0120289-04
Sample Site: Music Fountain

Date Collected: December 07, 2010

Date Received: December 08, 2010

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B 19th Edition	5.00	17.0	15-Dec-10	182	ug/L	1300	
Lead, Total	SM 3113 B 19th Edition	0.15	0.57	15-Dec-10	4.37	ug/L	15	

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd
Waunakee, WI 53597

Attn: Dan Reinke

Date: December 16, 2010
Client No: 10305

Sample No: 0120289-05
Sample Site: Kindergarden Fountain

Date Collected: December 07, 2010

Date Received: December 08, 2010

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
SDWA Inorganic Analysis								
Copper, Total	SM 3111 B 19th Edition	5.00	17.0	15-Dec-10	148	ug/L	1300	
Lead, Total	SM 3113 B 19th Edition	0.15	0.57	15-Dec-10	<0.15	ug/L	15	