

**Inorganics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-7; Lab: Pace Analytics**

| Storet Code | Description               | Result | Units | Qualifier  | MCL | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|---------------------------|--------|-------|------------|-----|-----------|-----------------------|--------------------|---------------|
| 1025        | FLUORIDE                  | 0.11   | MG/L  |            | 4   | MG/L      | 0.05                  | 0.007              | 1             |
| 1040        | NITRATE (N03-N)           | 6.4    | MG/L  |            | 10  | MG/L      | 0.05                  | 0.011              | 2             |
| 1038        | NITRATE-NITRITE (N03+N02) | 6.4    | MG/L  |            | 10  | MG/L      | 0.05                  | 0.025              | 3             |
| 1041        | NITRITE (N02-N)           | 0      | MG/L  | Non-detect | 1   | MG/L      | 0.05                  | 0.025              | 4             |

**Inorganics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-4; Lab: Pace Analytics**

| Storet Code | Description | Result | Units | Qualifier  | MCL   | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|-------------|--------|-------|------------|-------|-----------|-----------------------|--------------------|---------------|
| 1035        | MERCURY     | 0      | MG/L  | Non-detect | 0.002 | MG/L      | 0.0002                | 0.0001             | 1             |

**Inorganics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-3; Lab: Pace Analytics**

| Storet Code | Description    | Result | Units | Qualifier  | MCL   | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|----------------|--------|-------|------------|-------|-----------|-----------------------|--------------------|---------------|
| 1074        | ANTIMONY TOTAL | 0      | MG/L  | Non-detect | 0.006 | MG/L      | 0.002                 | 0.00028            | 1             |
| 1005        | ARSENIC        | 0      | MG/L  | Non-detect | 0.01  | MG/L      | 0.001                 | 0.00015            | 2             |
| 1045        | SELENIUM       | 0      | MG/L  | Non-detect | 0.05  | MG/L      | 0.001                 | 0.00025            | 3             |
| 1085        | THALLIUM TOTAL | 0      | MG/L  | Non-detect | 0.002 | MG/L      | 0.001                 | 0.00012            | 4             |

**Inorganics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-2; Lab: Pace Analytics**

| Storet Code | Description     | Result | Units | Qualifier  | MCL   | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|-----------------|--------|-------|------------|-------|-----------|-----------------------|--------------------|---------------|
| 1010        | BARIUM          | 0.018  | MG/L  |            | 2     | MG/L      | 0.01                  | 0.005              | 1             |
| 1075        | BERYLLIUM TOTAL | 0      | MG/L  | Non-detect | 0.004 | MG/L      | 0.001                 | 0.0005             | 2             |
| 1015        | CADMIUM         | 0      | MG/L  | Non-detect | 0.005 | MG/L      | 0.001                 | 0.0005             | 3             |
| 1020        | CHROMIUM        | 0      | MG/L  | Non-detect | 0.1   | MG/L      | 0.005                 | 0.0025             | 4             |
| 1036        | NICKEL          | 0      | MG/L  | Non-detect | 0.1   | MG/L      | 0.005                 | 0.0025             | 5             |

**Synthetic Organics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-5; Lab: Pace Analytics**

| Storet Code | Description | Result | Units | Qualifier  | MCL | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|-------------|--------|-------|------------|-----|-----------|-----------------------|--------------------|---------------|
| 2033        | ENDOTHALL   | 0      | UG/L  | Non-detect | 100 | UG/L      | 9                     | 2.7                | 1             |

**Synthetic Organics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-1; Lab: Pace Analytics**

| Storet Code | Description | Result | Units | Qualifier  | MCL | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|-------------|--------|-------|------------|-----|-----------|-----------------------|--------------------|---------------|
| 2046        | CARBOFURAN  | 0      | UG/L  | Non-detect | 40  | UG/L      | 0.9                   | 0.32               | 1             |
| 2105        | 2,4-D       | 0      | UG/L  | Non-detect | 70  | UG/L      | 0.1                   | 0.063              | 2             |
| 2031        | DALAPON     | 0      | UG/L  | Non-detect | 200 | UG/L      | 1                     | 0.78               | 3             |
| 2041        | DINOSEB     | 0      | UG/L  | Non-detect | 7   | UG/L      | 0.2                   | 0.15               | 4             |
| 2032        | DIQUAT      | 0      | UG/L  | Non-detect | 20  | UG/L      | 0.4                   | 0.15               | 5             |
| 2034        | GLYPHOSATE  | 0      | UG/L  | Non-detect | 700 | UG/L      | 6                     | 2.1                | 6             |

|      |                   |   |      |            |     |      |      |       |    |
|------|-------------------|---|------|------------|-----|------|------|-------|----|
| 2036 | OXAMYL (VYDATE)   | 0 | UG/L | Non-detect | 200 | UG/L | 2    | 0.41  | 7  |
| 2326 | PENTACHLOROPHENOL | 0 | UG/L | Non-detect | 1   | UG/L | 0.04 | 0.028 | 8  |
| 2040 | PICLORAM          | 0 | UG/L | Non-detect | 500 | UG/L | 0.1  | 0.056 | 9  |
| 2110 | 2,4,5-TP (SILVEX) | 0 | UG/L | Non-detect | 50  | UG/L | 0.2  | 0.12  | 10 |

**Volatile Organics-Sample Date: 9/26/13; Sampled by: K Killian; Sample ID: 35109892001-6; Lab: Pace Analytics**

| Storet Code | Description                    | Result | Units | Qualifier  | MCL   | MCL Units | Limit of Quantitation | Limit of Detection | Labslip Order |
|-------------|--------------------------------|--------|-------|------------|-------|-----------|-----------------------|--------------------|---------------|
| 2990        | BENZENE                        | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.1                | 1             |
| 2982        | CARBON TETRACHLORIDE           | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.19               | 2             |
| 2968        | O-DICHLOROBENZENE              | 0      | UG/L  | Non-detect | 600   | UG/L      | 0.5                   | 0.084              | 3             |
| 2969        | P-DICHLOROBENZENE              | 0      | UG/L  | Non-detect | 75    | UG/L      | 0.5                   | 0.12               | 4             |
| 2980        | 1,2-DICHLOROETHANE             | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.28               | 5             |
| 2977        | 1,1-DICHLOROETHYLENE           | 0      | UG/L  | Non-detect | 7     | UG/L      | 0.5                   | 0.23               | 6             |
| 2380        | CIS-1,2-DICHLOROETHYLENE       | 0      | UG/L  | Non-detect | 70    | UG/L      | 0.5                   | 0.12               | 7             |
| 2979        | TRANS-1,2-DICHLOROETHYLENE     | 0      | UG/L  | Non-detect | 100   | UG/L      | 0.5                   | 0.2                | 8             |
| 2964        | DICHLOROMETHANE                | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.19               | 9             |
| 2983        | 1,2-DICHLOROPROPANE            | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.25               | 10            |
| 2992        | ETHYLBENZENE                   | 0      | UG/L  | Non-detect | 700   | UG/L      | 0.5                   | 0.092              | 11            |
| 2989        | MONOCHLOROBENZENE (CHLOROBE..) | 0      | UG/L  | Non-detect | 100   | UG/L      | 0.5                   | 0.12               | 12            |
| 2996        | STYRENE                        | 0      | UG/L  | Non-detect | 100   | UG/L      | 0.5                   | 0.14               | 13            |
| 2987        | TETRACHLOROETHYLENE            | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.19               | 14            |
| 2991        | TOLUENE                        | 0      | UG/L  | Non-detect | 1000  | UG/L      | 0.5                   | 0.14               | 15            |
| 2378        | 1,2,4-TRICHLOROBENZENE         | 0      | UG/L  | Non-detect | 70    | UG/L      | 0.5                   | 0.13               | 16            |
| 2981        | 1,1,1-TRICHLOROETHANE          | 0      | UG/L  | Non-detect | 200   | UG/L      | 0.5                   | 0.2                | 17            |
| 2985        | 1,1,2-TRICHLOROETHANE          | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.31               | 18            |
| 2984        | TRICHLOROETHYLENE              | 0      | UG/L  | Non-detect | 5     | UG/L      | 0.5                   | 0.18               | 19            |
| 2976        | VINYL CHLORIDE                 | 0      | UG/L  | Non-detect | 0.2   | UG/L      | 0.5                   | 0.19               | 20            |
| 2955        | XYLENES, TOTAL                 | 0      | UG/L  | Non-detect | 10000 | UG/L      | 0.5                   | 0.25               | 21            |