

Synthetic Organics-Sample Date: 10/22/13; Sampled by: K Killian; Sample ID: 35113041001-1; Lab: Pace Analytical

Storet Code	Description	Result	Units	Qualifier	MCL	MCL Units	Limit of Quantitation	Limit of Detection	Labslip Order
2051	ALACHLOR (LASSO)	0	UG/L	Non-detect	2	UG/L	0.19	0.032	1
2050	ATRAZINE	0	UG/L	Non-detect	3	UG/L	0.095	0.02	2
2959	CHLORDANE	0	UG/L	Non-detect	2	UG/L	0.19	0.045	3
2005	ENDRIN	0	UG/L	Non-detect	2	UG/L	0.0095	0.0019	4
2065	HEPTACHLOR	0	UG/L	Non-detect	0.4	UG/L	0.038	0.0057	5
2067	HEPTACHLOR EPOXIDE	0	UG/L	Non-detect	0.2	UG/L	0.019	0.0028	6
2274	HEXACHLOROBENZENE (HCB)	0	UG/L	Non-detect	1	UG/L	0.095	0.01	7
2042	HEXACHLOROCYCLOPENTADIENE	0	UG/L	Non-detect	50	UG/L	0.095	0.011	8
2010	BHC-GAMMA (LINDANE)	0	UG/L	Non-detect	0.2	UG/L	0.019	0.0028	9
2015	METHOXYCHLOR	0	UG/L	Non-detect	40	UG/L	0.095	0.013	10
2037	SIMAZINE	0	UG/L	Non-detect	4	UG/L	0.066	0.042	11
2020	TOXAPHENE	0	UG/L	Non-detect	3	UG/L	0.95	0.58	12