



Wisconsin State Laboratory of Hygiene
 2601 Agriculture Drive, PO Box 7996
 Madison, WI 53707-7996
 (800)442-4618 • FAX (608)224-6213
<http://www.slh.wisc.edu>

Laboratory Report

D.F. Kurtycz, M.D., Medical Director • Charles D. Brokopp, Dr.P.H., Director

Environmental Health Division

Water Microbiology

WDNR LAB ID: 113133790

NELAP LAB ID: E37658

EPA LAB WI00007

WI DATCP ID: 105-415

WSLH Sample: BU042090

REINKE, DAN

5606 RIVER RD

WAUNAKEE WI 53597

Bill To

Billing ID: 731001

Customer ID: 10212

Fee Exempt

System Name: MADISON COUNTRY DAY SCHOOL

City: WAUNAKEE

Collection: Date/Time: 03/29/2010 08:30:00

Collected By: DAN REINKE

County: DANE

Source Code: PUBLIC DRINKING DISTRIBUTION

Monitor Point ID:

Sample Location: 5606 RIVER RD

Sample Description: SCIENCE ROOM TAP

PWS ID#: 113055800

WI Unique Well#:

Entry Point ID:

Date Received: 03/29/2010

Date Reported: 03/30/2010

Sample Reason: Compliance or Followup

System Type: NON-TRANSIENT NON-COMMUNITY

Analyses and Results:

Analysis Date	Lab Comment				
Analysis Method	Result	Units	LOD	LOQ	Report Limit
TOTAL COLIFORM - COLILERT - SM9223B	ABSENT				0
E.COLI - COLILERT - MUG - SM9223B	ABSENT				0

The water microbiology analyzes samples as received and not all samples are tested for preservation before analysis is performed. Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>

List of Abbreviations:

LOD = Level of detection

LOQ = Level of quantification

ND = None detected. Results are less than the LOD

Responsible Party: Sharon M. Kline

If there are questions about this report, please contact Barbara Gaffney at 608-224-6262.

The results in this report apply only to the sample specifically listed above. This report is not to be reproduced except in full.