

# DAVY LABORATORIES

115 6th Street S.  
P.O. Box 2076  
La Crosse, WI 54602-2076  
(608) 782-3130  
FAX (608) 784-8611  
www.davyinc.com



## LABORATORY ANALYSIS REPORT

Madison Country Day School  
5606 River Rd  
Waunakee, WI 53597

Attn: Dan Reinke

Date: April 02, 2010  
Client No: 10305

Sample No: 0030984-01  
Sample Site: Pump Room

Date Collected: March 29, 2010

Date Received: March 30, 2010


Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
-----------	--------	-----	--------	----------	--------	-------	-----	-----------

### SDWA Inorganic Analysis

Nitrate as N	EPA 300.0	0.150	0.500	31-Mar-10	5.95	mg/L	10	
--------------	-----------	-------	-------	-----------	------	------	----	--

Submitted by:

Davy Laboratories

  
Paul A. Harris, Laboratory Director

The laboratory analyses reported above were determined in accordance with methods from approved authoritative sources. Approved authoritative sources are defined and listed within the respective state certification codes. The results are representative of the samples only; conditions can be expected to vary at different times and under different sampling conditions. This report may not be reproduced, except in full, without the written approval of the laboratory. WI Certification Nos. 632021390 and 105000216, MN Certification No. 055-999-151, IA Certification No. 304