

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd.
Waunakee, WI 53597

Attn: Roger Seaver

Date: March 21, 2014
Client No: 10305

Sample No: 4030652-01
Sample Site: EI-Shop Sink

Date Collected: March 19, 2014

Date Received: March 20, 2014

Parameter	Method	MDL	LOQ/RL	Analyzed	Result	Units	MCL	Qualifier
-----------	--------	-----	--------	----------	--------	-------	-----	-----------

SDWA Inorganic Analysis

Nitrate as N	EPA 300.0	0.100	0.450	20-Mar-14	6.30	mg/L	10	
--------------	-----------	-------	-------	-----------	------	------	----	--

Submitted by:

Davy Laboratories

Paul A. Harris, Laboratory Director

The laboratory analyses reported above were determined in accordance with methods from approved authoritative sources. Approved authoritative sources are defined and listed within the respective state certification codes. The results are representative of the samples only; conditions can be expected to vary at different times and under different sampling conditions. This report may not be reproduced, except in full, without the written approval of the laboratory. WI Certification Nos. 632021390 and 105000216, MN Certification No. 055-999-151, IA Certification No. 304

DAVY LABORATORIES

115 6th Street S.
P.O. Box 2076
La Crosse, WI 54602-2076
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
5606 River Rd.
Waunakee, WI 53597

Attn: Roger Seaver

Date: March 21, 2014
Client No: 10305

Notes and Definitions

MDL Minimum Detection Level
LOQ/RL Limit of Quantitation/Reporting Limit
MCL Maximum Contaminant Level