



Wisconsin State Laboratory of Hygiene
 2601 Agriculture Drive, PO Box 7996
 Madison, WI 53707-7996
 (800)442-4618 • FAX (608)224-6213
<http://www.slh.wisc.edu>

Laboratory Report

D.F. Kurtycz, M.D., Medical Director • Charles D. Brokopp, Dr.P.H., Director

Environmental Health Division

Water Microbiology

WDNR LAB ID: 113133790

NELAP LAB ID: E37658 EPA LAB WI00007

WI DATCP ID: 105-415

WSLH Sample: BV060027

REINKE, DAN
5606 RIVER RD
WAUNAKEE WI 53597

Bill To
 Billing ID: 731001
 Customer ID: 10212

Fee Exempt

System Name: MADISON COUNTRY DAY SCHOOL
 City: WAUNAKEE
 Collection: Date/Time: 06/29/2011 10:00:00
 Collected By: DAN REINKE
 County: DANE
 Source Code: PUBLIC DRINKING DISTRIBUTION
 Sample Location: 5606 RIVER RD
 Sample Description: SCIENCE ROOM TAP

Monitor Point ID:
 PWS ID#: 113055800
 WI Unique Well#:
 Entry Point ID:
 Date Received: 06/29/2011
 Date Reported: 06/30/2011
 Sample Reason: Compliance or Followup
 System Type: NON-TRANSIENT NON-COMMUNITY

Analyses and Results:

Analysis Date	Lab Comment				
06/29/2011 10:51:03					
Analysis Method	Result	Units	LOD	LOQ	Report Limit
TOTAL COLIFORM - COLILERT - SM9223B	ABSENT				0
Total Coliform interpretation: Safe					
E. COLI - COLILERT - MUG - SM9223B	ABSENT				0

The water microbiology analyzes samples as received and not all samples are tested for preservation before analysis is performed. Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>

List of Abbreviations:
 LOD = Level of detection
 LOQ = Level of quantification
 ND = None detected. Results are less than the LOD

Responsible Party: Sharon Klunder Sharon Klunder, Microbiologist Supervisor

If there are questions about this report, please contact Barbara Gaffney at 608-224-6262.

The results in this report apply only to the sample specifically listed above. This report is not to be reproduced except in full.