



Wisconsin State Laboratory of Hygiene
 2601 Agriculture Drive, PO Box 7996
 Madison, WI 53707-7996
 (800)442-4618 - FAX (608)224-6213
<http://www.slh.wisc.edu>

Laboratory Report

D.F. Kurtycz, M.D., Medical Director - Charles D. Brokopp, Dr.P.H., Director

Environmental Health Division

WDNR LAB ID: 113133790 NELAP LAB ID: E37658 EPA LAB ID: WI00007 WI DATCP ID: 105-415

WSLH Sample: 27288001

Report To:
 DAN REINKE
 5606 RIVER RD
 WAUNAKEE, WI 53597

Invoice To:
 LUKE FELKER
 5606 RIVER RD
 WAUNAKEE, WI 53597
 Customer ID: 11305580

System Name: MADISON COUNTRY DAY SCHOOL
 City: WAUNAKEE
 Collection Date/Time: 06/27/2012 09:45
 Collected By: DAN REINKE
 County: 13 - Dane
 Source Code: DISTRIBUTION SYSTEM
 Collection Address:
 Location of Sample: LIBRARY TAP

Monitor Point ID: NA
 PWS ID#: 11305580
 WI Unique Well#:
 Entry Point ID:
 Date Received: 6/27/2012
 Date Reported: 6/28/2012
 Sample Type: COMPLIANCE OR FOLLOW-UP

Microbiology

Analysis Method	Result	Units	LOD	LOQ	RL	Prep Date	Analysis Date	By
Total Coliform - Colilert - SM9223B	Absent	/100mL				06/27/12 1225	06/28/12 1233	CMP
Total Coliform interpretation: SAFE								
E. Coli - Colilert - SM9223B	Absent	/100mL				06/27/12 1225	06/28/12 1233	CMP

The water microbiology analyzes samples as received and not all samples are tested for preservation before analysis is performed.

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.edu/nelap/>

List of Abbreviations

LOD = Level of detection
 LOQ = Level of quantification
 ND = None detected. Results are less than the LOD

Responsible Party: David Webb, Deputy Director, Environmental Health Division

If there are questions about this report, please contact the laboratory at 608-224-6202 or 800-442-4618.

The results in this report apply only to the sample specifically listed above. This report is not to be reproduced except in full.