



Wisconsin State Laboratory of Hygiene
 2601 Agriculture Drive, PO Box 7996
 Madison, WI 53707-7996
 (800)442-4618 • FAX (608)224-6213
<http://www.slh.wisc.edu>

Laboratory Report

D.F. Kurtycz, M.D., Medical Director • Charles D. Brokopp, Dr.P.H., Director

Environmental Health Division

Water Microbiology

WDNR LAB ID: 113133790

NELAP LAB ID: E37658 EPA LAB W100007

WI DATCP ID: 105-415

WSLH Sample: BT019091

REINKE, DAN
5606 RIVER RD
WAUNAKEE WI 53597

Bill To
 Billing ID: 731001
 Customer ID: 10212

Fee Exempt

System Name: MADISON COUNTRY DAY SCHOOL
 City: WAUNAKEE
 Collection: Date/Time: 09/22/2008 07:30:00
 Collected By: REINKE
 County: DANE
 Source Code: PUBLIC DRINKING DISTRIBUTION
 Sample Location:
 Sample Description: LOWER SCHOOL SCIENCE ROOM TAP

PWS ID#: 113055800
 WI Unique Well#:
 Entry Point ID:
 Date Received: 09/22/2008
 Date Reported: 09/23/2008
 Sample Reason: Compliance or Followup
 System Type: NON-TRANSIENT NON-COMMUNITY

Analyses and Results:

| Analysis Date | Lab Comment | | | | |
|-------------------------------------|-------------|-------|-----|-----|--------------|
| Analysis Method | Result | Units | LOD | LOQ | Report Limit |
| MMO-MUG TOTAL COLIFORM | ABSENT | | | | 0 |
| Total Coliform interpretation: Safe | | | | | |

The water microbiology analyzes samples as received and not all samples are tested for preservation before analysis is performed. Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/nelap/>

List of Abbreviations:
 LOD = Level of detection
 LOQ = Level of quantification
 ND = None detected. Results are less than the LOD

Responsible Party: Sharon M. Kessler

If there are questions about this report, please contact Barbara Gaffney at 608-224-6262. The results in this report apply only to the sample specifically listed above. This report is not to be reproduced except in full.