



Wisconsin State Laboratory of Hygiene  
2601 Agriculture Drive, PO Box 7996  
Madison, WI 53707-7996  
(800)442-4618 - FAX (608)224-6213  
<http://www.slh.wisc.edu>

# Laboratory Report

Environmental Health Division

**WSLH Sample: 642390001**

Report To:  
ROGER SEAVER  
5606 RIVER RD  
WAUNAKEE, WI 53597-9510

Invoice To:  
LUKE FELKER  
5606 RIVER RD  
WAUNAKEE, WI 53597  
Customer ID: 11305580

System Name: MADISON COUNTRY DAY SCHOOL  
City: WAUNAKEE  
Collection Date/Time: 09/14/2022 06:45  
Collected By: ROGER SEAVER  
County: 13 - Dane  
Source Code: E - Entry Point  
Collection Address: 5606 RIVER RD  
Location of Sample: MOP SINK IN PRESSURE TANK

Monitor Point ID: E1  
PWS ID#: 11305580  
WI Unique Well#: BN633  
Entry Point ID: 1  
Date Received: 9/14/2022  
Date Reported: 9/16/2022  
Sample Type: D-Rout Dist Comp & FU

## Inorganic Chemistry

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 09/15/22 09:12		Analysis Date: 09/15/22 09:12			
Nitrate + Nitrite (as N)	EPA 353.2	7.35	mg/L	0.160	0.530



Wisconsin State Laboratory of Hygiene  
2601 Agriculture Drive, PO Box 7996  
Madison, WI 53707-7996  
(800)442-4618 - FAX (608)224-6213  
<http://www.slh.wisc.edu>

# Laboratory Report

Environmental Health Division

**WSLH Sample: 642390001**

WDNR LAB ID:113133790    NELAP LAB ID:2091    EPA LAB ID:WI00007, WI00008    WI DATCP ID:105-415

## List of Abbreviations:

LOD = Level of detection  
LOQ = Level of quantification (for PFAS the LOQ = MRL)  
ND = None detected. Results are less than the LOD  
F next to result = Result is between LOD and LOQ  
Z next to result = Result is between 0 (zero) and LOD  
if LOD=LOQ, Limits were not statistically derived

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes

see <http://www.slh.wisc.edu/about/compliance/nelac-laboratory-accreditation>

Results, LOD and LOQ values have been adjusted for analytical dilutions and percent moisture where applicable.

Results relate only to the items tested.

This Laboratory Report shall not be reproduced except in full, without written approval of the laboratory.

The water microbiology unit analyzes samples as received and not all samples are tested for preservation before analysis is performed.

## Responsible Party

Inorganic Chemistry: Graham Anderson, Supervisor 608-224-6281  
Metals: Graham Anderson, Supervisor 608-224-6281  
Organics: Erin Mani, Supervisor 608-224-6269  
Environmental Toxicology: Dawn Perkins, Supervisor 608-224-6230  
Water Microbiology: Martin Collins, Supervisor 608-224-6239  
Radiochemistry: David Webb, Division Director 608-224-6227