

DAVY LABORATORIES

A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
Attn: Roger Seaver
5606 River Rd.
Waunakee, WI 53597

Date: October 06, 2022
Client No: 10305

Sample No: 2210437-03 Sample Collected: 14-Sep-22 06:11 Sample Received: 15-Sep-22 09:35
Sample Site: D6

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
Laboratory Results										
Copper, Total	78.3	µg/L	46.0	152	1	29-Sep-22 11:12	29-Sep-22 11:17	SM 3111 B-2011	1300	J
Lead, Total	<1.08	µg/L	1.08	3.59	1	24-Sep-22 09:08	24-Sep-22 09:15	SM 3113 B-2010	15	

DAVY LABORATORIES

A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
Attn: Roger Seaver
5606 River Rd.
Waunakee, WI 53597

Date: October 06, 2022
Client No: 10305

Sample No: 22I0437-04
Sample Site: D7

Sample Collected: 14-Sep-22 06:15

Sample Received: 15-Sep-22 09:35

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
-----------	--------	-------	-----	--------	----------	----------	----------	--------	-----	-----------

Laboratory Results

Copper, Total	88.6	μg/L	46.0	152	1	29-Sep-22 11:12	29-Sep-22 11:17	SM 3111 B-2011	1300	J
Lead, Total	1.72	μg/L	1.08	3.59	1	24-Sep-22 09:08	24-Sep-22 09:15	SM 3113 B-2010	15	J

DAVY LABORATORIES

A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
Attn: Roger Seaver
5606 River Rd.
Waunakee, WI 53597

Date: October 06, 2022
Client No: 10305

Sample No: 22I0437-05
Sample Site: D10

Sample Collected: 14-Sep-22 06:19

Sample Received: 15-Sep-22 09:35

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
Laboratory Results										
Copper, Total	118	µg/L	46.0	152	1	29-Sep-22 11:12	29-Sep-22 11:17	SM 3111 B-2011	1300	J
Lead, Total	<1.08	µg/L	1.08	3.59	1	24-Sep-22 09:08	24-Sep-22 09:15	SM 3113 B-2010	15	

DAVY LABORATORIES

A Division of Davy Engineering Co., Inc.
 115 6th Street South
 La Crosse, WI 54601
 (608) 782-3130
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
 Attn: Roger Seaver
 5606 River Rd.
 Waunakee, WI 53597

Date: October 06, 2022
 Client No: 10305

Sample No: 22I0437-06 Sample Collected: 14-Sep-22 06:21 Sample Received: 15-Sep-22 09:35
 Sample Site: D13

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
Laboratory Results										
Copper, Total	69.2	µg/L	46.0	152	1	29-Sep-22 11:12	29-Sep-22 11:17	SM 3111 B-2011	1300	J
Lead, Total	<1.08	µg/L	1.08	3.59	1	24-Sep-22 09:08	24-Sep-22 09:15	SM 3113 B-2010	15	

DAVY LABORATORIES

A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
www.davyinc.com



LABORATORY ANALYSIS REPORT

Madison Country Day School
Attn: Roger Seaver
5606 River Rd.
Waunakee, WI 53597

Date: October 06, 2022
Client No: 10305

Sample No: 22I0437-07
Sample Site: D14

Sample Collected: 14-Sep-22 06:23

Sample Received: 15-Sep-22 09:35

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
-----------	--------	-------	-----	--------	----------	----------	----------	--------	-----	-----------

Laboratory Results

Copper, Total	184	µg/L	46.0	152	1	29-Sep-22 11:12	29-Sep-22 11:17	SM 3111 B-2011	1300	
Lead, Total	<1.08	µg/L	1.08	3.59	1	24-Sep-22 09:08	24-Sep-22 09:15	SM 3113 B-2010	15	